NEBRASKA ADMINISTRATIVE CODE

TITLE 229 - DEPARTMENT OF LABOR

CHAPTER 3 - NOTICE OF INSTALLATION OF BOILERS AND PRESSURE VESSELS

- 001. This chapter is adopted pursuant to Neb. Rev. Stat. §48-727.
- Owners, users and lessees of all jurisdictional boilers and pressure vessels now in use or installed ready for use in the state of Nebraska, shall report to the Commissioner, giving the location, type, capacity, age, and date of installation of the boiler or pressure vessel. Such boilers and pressure vessels shall be designed and certified per applicable ASME codes, or they shall have equivalent safety measures consistent with codes recognized in *Neb. Rev. Stat.* §48-727 of the Boiler Inspection Act to obtain an Certificate of Inspection.
- 003. At least ten days prior to the installation, construction, or operation of any new, used, or reinstalled jurisdictional boiler or pressure vessel, the contractor, person, or entity responsible for installing or constructing the boiler or pressure vessel shall give notice of the proposed installation to the Commissioner using the electronic/on-line form provided on the Department's website. The notice shall designate the proposed place and date of installation, the type and capacity of the boiler or pressure vessel, the use to be made of the boiler or pressure vessel, the name of the company which manufactured the boiler or pressure vessel, and whether the boiler or pressure vessel is new or used or being reinstalled. Any inspection of a new installation for which notice was not given to the Commissioner in accordance with this chapter and *Neb. Rev. Stat.* §48-730 shall be deemed a special inspection under 229 NAC 7 §005(A)(2); except that if the installation was done as a part of a repair process and written notice was given to the Commissioner prior to actual installation, the inspection shall not be considered a special inspection under 229 NAC 7 §005(A)(2).
- O04. All new installations of boilers, water heaters or pressure vessels shall be inspected by the state chief boiler inspector or a deputy state boiler inspector prior to operation of the unit.
- 005. If an owner or user enters into a contract with an installer and in that contract the installer is responsible for all inspection, permit or other fees, a copy of that contract shall be given to the state boiler inspector at the time of the initial inspection of the unit.

229 NAC 3 Page 1 of 1